

Speed Post

No. MER/RTRWH/2015- 1115

Government of India,
Central Ground Water Board,
Mid-Eastern Region, 6-7th Floor,
Lok Nayak Jaiprakash Bhawan,
Dak Bungalow, Patna-800001

Dated: 23/11/2015

24

To
The Managing Director,
Pranami Estates Pvt. Ltd.
41 Court Road,
Ranchi – 834001

Sub: Your submission of Technical feasibility cum Project Report for Rain water Harvesting for “Santushti – Residential Complex” at Konka, Ranchi dated 02/11/2015

Sir,

With reference to the above cited application, the report has been assessed and have been found that design meets the laid down conditions and hence stands approved subject to the following conditions along with self-declarations made in the report.

1. Construction should strictly adhere to the submitted plan;
2. Efficiency of installed filter media should be checked before making it full-time operational, both in terms of physical, chemical and biological quality of recharge water. Results may be submitted to this office;
3. Only rainwater should be used and not to be mixed up with discharges of any ETP;
4. Exclusive covered pipeline should be used apart from main storm-water drainage systems with installed control system for excess water transfer from RTRWT system to storm water drainage system and not vice-versa;

This is for your kind intimation please.

Yours faithfully


23-11-15

(G. K. Roy)
Scientist-D &
Head of Office